



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-4312AT0342

Registration Number
Registriernummer

Field of Application

Anwendungsbereich

products of gas supply

Produkte der Gasversorgung

Owner of Certificate

Zertifikatinhaber

ENOLGAS Bonomi Spa

Via Europa 227, I-25062 Concesio (BS)

Distributor

Vertreiber

ENOLGAS Bonomi Spa

Via Europa 227, I-25062 Concesio (BS)

Product Category

Produktart

gas fittings: Shut-off valve $\leq$ MOP 5 (4312)

Product Description

Produktbezeichnung

Straight pattern ball valve for gas installation

Model

Modell

BON.GAS; TOP.GAS

Test Reports

Prüfberichte

supplement test: 1111058-001 from 19.10.2021 (TTR)

laboratory control test: 1109869-001 from 23.02.2021 (TTR)

type testing: 20161118 from 18.11.2016 (TTR)

Test Basis

Prüfgrundlagen

DIN EN 331 (01.04.2016)

Date of Expiry / File No. 31.08.2026 / 21-0571-GNV

Ablaufdatum / Aktenzeichen

05.11.2021 Kö A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
fuel gases according to G 260: 03.2013	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
BON.GAS; TOP.GAS	pressure class: MOP 5 nominal diameter: DN 15 max. operating pressure: 5 bar	
BON.GAS; TOP.GAS	pressure class: MOP 5 nominal diameter: DN 20 max. operating pressure: 5 bar	
BON.GAS; TOP.GAS	pressure class: MOP 5 nominal diameter: DN 25 max. operating pressure: 5 bar	
BON.GAS; TOP.GAS	pressure class: MOP 5 nominal diameter: DN 32 max. operating pressure: 5 bar	
BON.GAS; TOP.GAS	pressure class: MOP 5 nominal diameter: DN 40 max. operating pressure: 5 bar	
BON.GAS; TOP.GAS	pressure class: MOP 5 nominal diameter: DN 50 max. operating pressure: 5 bar	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
BON.GAS	reduced passage
TOP.GAS	full passage

certified Components*zertifizierte Bauteile / Werkstoffe*

Registr. No. <i>Registrier-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
NG-5146AR0617	Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening	LOCTITE® 2701/LOCTITE® 2701	Henkel AG & Co. KGaA
NG-5112BN0160	Elastomer material for seals in gas appliances	01/I70 HNBR/01/I70 HNBR (H-HBR 70 SHORE gelb)	LAV.EL GOMMA S.r.l.
NG-5162BP5578	Materials for greasing of gas appliance	GRASSO L 100/GRASSO L FAPA di Dott. Enrico Nosari S.a.s. 100	
NG-5146BQ0134	Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening	Loxeal 83-50/Loxeal 83-50	LOXEAL S.r.l.

Hints of Utilization / Remarks*Verwendungshinweise / Bemerkungen*

ambient temperature range: -20...+60 °C

connection: on both sides internal thread Rp 1/2...Rp 2, at one side also external thread R 1/2...R 2, each according to DIN EN 10226-1


 DVGW